

CENTRAL POWER RESEARCH INSTITUTE

Switchgear Testing & Development Station Govindpura, Bhopal-23

SUPPLEMENTARY TEST LABORATORY PROVISIONAL TEST REPORT

SEP 2018

CPRIBPLSTNC1819T0371 Test Report No. & Date

M/s Penclotek Panel Pvt. Ltd., Customer his reference and address

G-296. Phase-II. Masori Gulathi Road.

Industrial Area, Ghaziabad, U.P

M/s Penclotek Panel Pvt. Ltd.. Manufacturer, his reference & address

G-296, Phase-II, Masori Gulathi Road.

Industrial Area, Ghaziabad, U.P.

415V, 600A LT Panel Particulars of apparatus tested

Nil Designation

Outdoor Type

STNC1819S0230 Identification No./Sample code No.

Sl.No.

PPPL/IP65/STL/02 Drawing No.(Under revision) 31.8.2018 & 4.9.2018 Date (s) of test (s)

No.of samples tested

Degree of Protection IP-65 Test conducted

The above test was conducted on the sample Particulars of test conducted as per standard. The wire of specified diameter did not enter the enclosure after test and no traces of powder observed inside the sample after IP-6X test. No traces of water observed inside the sample after IPX5 test. Sample withstood HV test at 1.0 kVrms for one minute after IPX5 test.

As per Cl. C12, C13.4 & C14 of IS/IEC: Test in accordance with standard/

60947-1.2004 Specification

Customer's requirement/deviation if any

Customer's representative 1) Mr. Pamod Upadhyay 2) Mr. Pradeep Kumar

Other than Customer's representative

Note:

TEST ENGINEER

This is only a provisional report. The final test report along with drawings and other documents and other documents are a final test report along with drawings and other documents. The results are not binding on the testing authority until the final test report is issued. *** Power Research institute Corrections/erasing invalidate the test report.

Nil

प्रमान रिकामान्य हैं और atopment राधिन्यपुरा भीपाल - 462025 apura Bhagal 462 023