

**CENTRAL POWER RESEARCH INSTITUTE
(MEMBER OF STL)**



TEST REPORT

CPRI

Test Report Number CPRIBPLSTNB1819T0668

Date : 15 November 2019

Ratings assigned by manufacturer

Test sample	415V, 4000A, LT Panel (Non-Extendable)
Type	PCC/MCC
Designation	Nil
Serial number	Nil
Rated operational voltage	415 V
Rated current	4000 A
Rated insulation voltage	660 V
Rated frequency	50 Hz
Number of phases	Three phase+Neutral
Rated short-time current	65 kArms for 1.0 second with initial peak of 143 kA

(VIPUL SHARMA)
TEST ENGINEER